



REQUEST FOR QUOTATION

Date: 07 July 2023
RFQ No.: 100-23-02-407

Name of Company: _____
Address: _____
Name of Store/Shop: _____
Address: _____
TIN: _____
PhilGEPS Registration Number: _____

The City Government of Pasig, through the Bids and Awards Committee (BAC), intends to procure **Supply and Installation of Medical Carbon Dioxide Automatic Manifold System - PCGH** with an Approved Budget for the Contract (ABC) of **Php 800,000.00**, in accordance with **Section 53.9** of the 2016 revised Implementing Rules and Regulations of Republic Act No. 9184. Please quote your best offer for the item in the table below.

The Project shall be awarded as One Project having several items that shall be awarded as one contract. Quotations received exceeding each total Cost per Item and/or the total Approved Budget for the Contract shall be rejected.

Item No.	Item Description	Brand Name <small>(PLEASE DO NOT LEAVE BLANK)</small>	QTY	UOM	Approved Budget		Price Offer	
					Unit Cost	Total Cost	Unit cost	Total Cost
1	SUPPLY AND INSTALLATION OF MEDICAL CARBON DIOXIDE AUTOMATIC MANIFOLD SYSTEM, - A. SPECIFICATIONS - 1. Installers and Designers must have the capability and competency for the specialized knowledge required to meet the Standard Guidelines of the National Fire Protection Association 2018 Edition (NFPA -99 - Medical Health Care Facilities) design requirements. - 2. Carbon Dioxide Automatic Manifold System, Stack Mounted - 3. System Capacity: * Manifold Capacity is 3 tank cylinders @ left bank and 3 tank cylinders @ right tank = 6 tank cylinders * Manifold Pressure is 1800 to 2000 PSI * Hospital Demand: 70 PSI - 4. Power Rating: 230VAC - 60Hz ,1 phase		1	unit	800,000.00	800,000.00		



<ul style="list-style-type: none"> - 5. Fully Automatic Change Over - 6. Complete with headers assembly and individual isolation valves - 7. With Bypass valve and regulator - 8. Provide tank protection, individual isolation valve, flexible hose with check valves and Inficon leak detector. - 9. The LED Control System must be NEMA 12 rated - 10. PLC/HMI Control Panel Automatic Lead/Lag sequencing and alternation are required. - 11. A separate circuit breaker disconnects for each compressor, internal to the main control cabinet and protected by the safety interlock of that cabinet. - 12. Panel High and Low regulator, with visible and audible alarm indication for High and Low discharge. - 13. Refer to TOR 					
Note: Other terms and conditions are stipulated in the attached Terms of Reference, if any.	Total	800,000.00			
DELIVERY TERM: Please refer to the Terms of Reference.					

**Indicate the BRAND NAME or MANUFACTURER NAME and the specific MODEL to be offered or attach a BROCHURE for the offered item; items including but not limited to clothing, vehicle, equipment, devices, electronics, machines, drugs, medicines, medical supplies must be branded or at the very least, manufacturer shall be indicated.*



Submit this Quotation (Accomplished and duly signed by the Owner or the respective Authorized Representative indicated in the Secretary’s Certificate/Special Power of Attorney) not later than the closing date specified in the Bid Notice Abstract posted in PhilGEPS website along with the following documents:


- **Mayor’s/Business Permit** (or a recently expired Mayor’s/Business permit together with the official receipt as proof that the prospective bidder has applied for renewal within the period prescribed by the concerned local government unit subject to submission of the Mayor’s Permit before the award of contract). The nature of business as stated in the Mayor’s/Business Permit should at the very least be similar or related to the project to be bid.
- **PhilGEPS Registration Number**
- **Income Tax Return** - Latest Income or Business Tax Returns filed and paid through the BIR Electronic Filing and Payment System (EFPS).

In accordance with Revenue Regulation No. 3-2005, the above-mentioned tax returns shall refer to the following:

1. Latest income Tax Return (ITR) - For participants already with an Annual ITR, latest ITR shall refer to the ITR for the preceding Tax Year be it on a calendar or fiscal year. For new establishments which, therefore, have no annual ITR yet, it shall refer to the most recent quarter’s ITR.
2. Latest Business Tax Return - refers to the Value Added Tax (VAT) or Percentage Tax returns covering the previous six (6) months.

Caruncho Avenue, Brgy. San Nicolas, Pasig City, Philippines 1600

 (02) 8643-1111 * (02) 8641-1111 loc 1461 *  bidsandawards@pasigcity.gov.ph *

 pasigcity.gov.ph

- Accomplished and notarized **Omnibus Sworn Statement** ([https://www.gppb.gov.ph/assets/forms/Omnibus%20Sworn%20Statement\(Revised\).docx](https://www.gppb.gov.ph/assets/forms/Omnibus%20Sworn%20Statement(Revised).docx))
- **Proof of Authorization: Secretary's Certificate** if corporation, or **Special Power of Attorney**, if individual.

ADDITIONAL REQUIREMENTS:

For Procurement of Drugs and Medicines:

Documents from the Food and Drug Administration (FDA):

- Certificate of Product Registration;
- Certificate of Good Manufacturing Practice;
- License to Operate;
- Batch Release Certificate *(for vaccines, toxoids and immunoglobulins only) [to be submitted upon delivery];* and
- Certificate of Analysis *(for anesthesia and antibiotics) [to be submitted upon delivery].*

If the Supplier is not the Manufacturer, a certification from the Manufacturer that the supplier is an authorized distributor/dealer of the products/items.

Please submit the accomplished Quotation and required documents on or before the deadline of submission at the Bids and Awards Committee (BAC) through the **Procurement Management Office (BAC Secretariat Office), 4th Floor, Pasig City Hall, San Nicolas, Pasig City.**

All documents should be submitted in a sealed brown envelope addressed to the "Bids and Awards Committee, 4th Floor, Pasig City Hall", and properly marked with the Project Title as provided herein.

The CITY GOVERNMENT OF PASIG reserves the right to reject any and all bids, declare a failure of bidding, or not award the contract at any time prior to contract award in accordance with Sections 35.6 and 41 of the 2016 revised IRR of RA No. 9184, without thereby incurring any liability to the affected bidder or bidders.

For any clarification, you may contact us at telephone no. (02) 8641-1111 / (02) 8643-1111 loc. 1461 or email address at bidsandawards@pasigcity.gov.ph

ATTY. PONCE MIGUEL D. LOPEZ JR.

Officer in Charge, Procurement Management Office

I hereby certify that I have read and agree to this Request for Quotation, its Terms of Reference, and Bid Bulletin/s, if any. I further certify that the products to be delivered will conform to the specifications stated in the Item Description.

Conforme:

_____	_____
Signature over Printed Name	Position
Duly authorized to sign quotation/offer for and on behalf of _____	
(Please indicate Company Name)	

Caruncho Avenue, Brgy. San Nicolas, Pasig City, Philippines 1600

(02) 8643-1111 * (02) 8641-1111 loc 1461 * bidsandawards@pasigcity.gov.ph *

pasigcity.gov.ph

TERMS OF REFERENCE

FOR THE SUPPLY AND INSTALLATION OF MEDICAL CARBON DIOXIDE AUTOMATIC MANIFOLD SYSTEM

I. LOCATION:

Pasig City General Hospital, M. Eusebio Ave., Maybunga, Pasig City

II. DELIVERY PERIOD : 90 days

TERMS AND CONDITION


A. QUALIFICATION OF CONTRACTORS

- 1 The Contractor must be in the field or business of supply and installation of air-conditioning units, must have an experience or track record in this field for the last 15 to 20 years.
2. Must have done similar installation of Carbon Dioxide Automatic Manifold System in Hospitals.
3. The contractor must provide training in the actual operation and maintenance of the manifold system.

B. SCOPE OF WORKS

1. Isolate power supply
2. Dismantling of defective Manifold and Headers with pigtails
3. Brazing of copper tube type- L and installation of headers support
4. Testing and Commissioning
5. Leak Testing of whole system

Prepared By :


Engr. Samuel P. Fernandez
Head – Maintenance Department