



BID BULLETIN NO. 01

Date: **19 January 2024**

ITB No.: **bac-24-0105g**

Project Name: **Supply, Delivery and Installation of Parts of Fire Suppression System in PCGH Data Center - MISO**

ABC: Php 2,403,880.35

To all prospective bidders:

This Bid Bulletin is issued to clarify, supplement, modify and/or revise the particular sections in the Bid and Contract Documents as stipulated in the Bidding Documents issued on 05 January 2024. The Bidders shall take note of the following items carefully and consider them in the preparation of their bid proposals, as they shall form part of the CONTRACT DOCUMENTS.

Item	Previous Specification/ Clarification/Request to Consider	Amendment/Response to Clarification
1	<p>PREVIOUS SECTION I. INVITATION TO BID XXX XXX XXX</p> <p>7. Bids must be duly received by the Procurement Management Office through manual submission at the office address indicated below, on or before January 24, 2024 9:30 A.M. Late bids shall not be accepted. XXX XXX XXX</p> <p>9. Bid opening shall be on January 24, 2024 9:30 A.M. at the given address below. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity. XXX XXX XXX</p>	<p>AMENDMENT TO SECTION I. INVITATION TO BID XXX XXX XXX</p> <p>7. Bids must be duly received by the Procurement Management Office through manual submission at the office address indicated below, on or before January 26, 2024, 9:30 A.M. Late bids shall not be accepted. XXX XXX XXX</p> <p>9. Bid opening shall be on January 26, 2024, 9:30 A.M. at the given address below. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity. XXX XXX XXX</p>

<p>2</p>	<p style="text-align: center;">PREVIOUS REMINDERS</p> <p style="text-align: center;">XXX XXX XXX</p> <p>BIDDING DOCUMENTS AND AVAILABILITY FEE</p> <ul style="list-style-type: none"> • Bidding Documents: <ul style="list-style-type: none"> ➤ January 5, 2024 to January 24, 2024 until 9:30 AM ➤ 8:00 am to 5:00 pm and upon payment of applicable fees for the Bidding Documents at the City Treasurer’s Office <p style="text-align: center;">XXX XXX XXX</p> <p>REMINDERS:</p> <ul style="list-style-type: none"> • The deadline for the submission of bid is on January 24, 2024 (Wednesday) at 9:30 AM at the BAC Secretariat’s Office, 4th Floor Pasig City Hall, Caruncho Ave., San Nicolas Pasig City. The digital clock at the BAC Secretariat’s Office that is set to the Philippine Time (PhST) shall be used as reference in determining the time for the submission of bids, hence participating bidders are advised to synchronize their timepiece with the said digital clock. Late bids or those who submitted after 9:30 AM of January 24, 2024 (Wednesday) shall not be accepted. <p style="text-align: center;">XXX XXX XXX</p>	<p style="text-align: center;">AMENDMENT TO REMINDERS</p> <p style="text-align: center;">XXX XXX XXX</p> <p>BIDDING DOCUMENTS AND AVAILABILITY FEE</p> <ul style="list-style-type: none"> • Bidding Documents: <ul style="list-style-type: none"> ➤ January 5, 2024 to January 26, 2024 until 9:30 AM ➤ 8:00 am to 5:00 pm and upon payment of applicable fees for the Bidding Documents at the City Treasurer’s Office <p style="text-align: center;">XXX XXX XXX</p> <p>REMINDERS:</p> <ul style="list-style-type: none"> • The deadline for the submission of bid is on January 26, 2024 (Friday) at 9:30 AM at the BAC Secretariat’s Office, 4th Floor Pasig City Hall, Caruncho Ave., San Nicolas Pasig City. The digital clock at the BAC Secretariat’s Office that is set to the Philippine Time (PhST) shall be used as reference in determining the time for the submission of bids, hence participating bidders are advised to synchronize their timepiece with the said digital clock. Late bids or those who submitted after 9:30 AM of January 26, 2024 (Friday) shall not be accepted. <p style="text-align: center;">XXX XXX XXX</p>
-----------------	---	--

	<ul style="list-style-type: none"> Bid opening shall be on January 24, 2024 (Wednesday) at 10:00 AM at 7th Floor Meeting Room, Pasig City Hall, Caruncho Ave., San Nicolas Pasig City. Bids will be opened in the presence of the bidders' representatives who choose to attend. xxx xxx xxx
	<ul style="list-style-type: none"> Bid opening shall be on January 26, 2024 (Friday) at 10:00 AM at 7th Floor Meeting Room, Pasig City Hall, Caruncho Ave., San Nicolas Pasig City. Bids will be opened in the presence of the bidders' representatives who choose to attend. xxx xxx xxx

3	PREVIOUS SECTION VII. TECHNICAL SPECIFICATIONS	AMENDMENT TO SECTION VII. TECHNICAL SPECIFICATIONS									
	<table border="1"> <thead> <tr> <th style="width: 10%;">ITEM</th> <th style="width: 90%;">SPECIFICATION</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1</td> <td> Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15, UL/FM approved. xxx xxx xxx </td> </tr> </tbody> </table>	ITEM	SPECIFICATION	1	Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15, UL/FM approved. xxx xxx xxx	<table border="1"> <thead> <tr> <th style="width: 10%;">ITEM</th> <th style="width: 90%;">SPECIFICATION</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1</td> <td> Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder SIEX Cylinder or its equivalent complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15 SIEX model FEDR15 or its equivalent UL/FM approved. xxx xxx xxx </td> </tr> </tbody> </table>	ITEM	SPECIFICATION	1	Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder SIEX Cylinder or its equivalent complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15 SIEX model FEDR15 or its equivalent UL/FM approved. xxx xxx xxx	
ITEM	SPECIFICATION										
1	Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15, UL/FM approved. xxx xxx xxx										
ITEM	SPECIFICATION										
1	Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder SIEX Cylinder or its equivalent complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15 SIEX model FEDR15 or its equivalent UL/FM approved. xxx xxx xxx										

4	PREVIOUS SECTION VII. TECHNICAL SPECIFICATIONS/TOR	AMENDMENT TO SECTION VII. TECHNICAL SPECIFICATIONS/TOR									
	<table border="1"> <thead> <tr> <th style="width: 10%;">ITEM</th> <th style="width: 90%;">SPECIFICATION</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1</td> <td> Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15, UL/FM approved. xxx xxx xxx </td> </tr> </tbody> </table>	ITEM	SPECIFICATION	1	Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15, UL/FM approved. xxx xxx xxx	<table border="1"> <thead> <tr> <th style="width: 10%;">ITEM</th> <th style="width: 90%;">SPECIFICATION</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1</td> <td> Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder SIEX Cylinder or its equivalent complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15 SIEX model FEDR15 or its equivalent UL/FM approved. xxx xxx xxx </td> </tr> </tbody> </table>	ITEM	SPECIFICATION	1	Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder SIEX Cylinder or its equivalent complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15 SIEX model FEDR15 or its equivalent UL/FM approved. xxx xxx xxx	
ITEM	SPECIFICATION										
1	Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15, UL/FM approved. xxx xxx xxx										
ITEM	SPECIFICATION										
1	Supply and Installation of Parts of Fire Suppression in PCGH Data Center xxx xxx xxx Amount: Php 839,598.14 - Siex Cylinder SIEX Cylinder or its equivalent complete with Accessories. (Fill Range 11-5KG) Amount: Php 76,409.42 - Radial nozzle, 360°, 1", model FEDR15 SIEX model FEDR15 or its equivalent UL/FM approved. xxx xxx xxx										


5	<p>CLARIFICATION/QUERIES FROM PROSPECTIVE BIDDER, SECTION: III. BID DATA SHEET</p> <p>1. For SLCC accepted similar contract, can we use our previous project for "Rehabilitation and Replacement of IG 55"?</p>	<p style="text-align: right;">TO</p> <p>RESPONSE CLARIFICATION/QUERIES FROM PROSPECTIVE BIDDER, SECTION: III. BID DATA SHEET</p> <p>1. SLCC will be subject for evaluation of BAC & TWG</p>
----------	--	---

Bidders who have already submitted bids are hereby informed that they are allowed to modify or withdraw their bids, if necessary, before the scheduled opening of bid envelopes.

For modifications in your original submitted bid, kindly submit new bidding documents (sealed and marked as "Modified Bid") and have these received at the

Office of the Bids and Awards Secretariat. Bid modifications received after the deadline shall not be considered and shall be returned to the bidder unopened.

Conforme:


JOHN CARLO FATALLO
 END-USER REPRESENTATIVE
 Signature Over Printed Name

SGD
ATTY. JOSEPHINE C. LATI-BAGAOISAN
 Chairperson