



BID BULLETIN NO. 02

Date: **11 August 2023**

ITB No.: **PB-08-23-2023-01**

Project Name: **Installation of Dry Stand Pipe and Replacement of Fire Hose Cabinet Accessories at Muslim Compound, Magdalena HOA, Sanchez HOA, Coco Ville HOA, V. Baltazar St., Brgy. Sto. Tomas, Pasig City (REBID)**

ABC: Php3,920,314.02

To all prospective bidders:

This Bid Bulletin is issued to clarify, supplement, modify and/or revise the particular sections in the Bid and Contract Documents as stipulated in the Bidding Documents issued on 04 August 2023. The Bidders shall take note of the following items carefully and consider them in the preparation of their bid proposals, as they shall form part of the CONTRACT DOCUMENTS.

Item	Previous Specification/ Clarification/Request to Consider	Amendment/Response to Clarification												
1	<p>PREVIOUS SECTION VI. SPECIFICATIONS</p> <table border="1"> <thead> <tr> <th>ITEM</th> <th>DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>2.0</td> <td>EARTHWORKS INSTALLATION OF DRY STAND PIPE 3.2 Pipe Laying and Fittings FITTINGS (USE G.I FITTINGS SCHED .40)</td> </tr> <tr> <td colspan="2" style="text-align: center;">XXX XXXXXX</td> </tr> </tbody> </table>	ITEM	DESCRIPTION	2.0	EARTHWORKS INSTALLATION OF DRY STAND PIPE 3.2 Pipe Laying and Fittings FITTINGS (USE G.I FITTINGS SCHED .40)	XXX XXXXXX		<p>AMENDMENT TO SECTION VI. SPECIFICATIONS</p> <table border="1"> <thead> <tr> <th>ITEM</th> <th>DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>2.0</td> <td>EARTHWORKS INSTALLATION OF DRY STAND PIPE 3.2 Pipe Laying and Fittings FITTINGS (USE B.I FITTINGS SCHED .40)</td> </tr> <tr> <td colspan="2" style="text-align: center;">XXX XXXXXX</td> </tr> </tbody> </table>	ITEM	DESCRIPTION	2.0	EARTHWORKS INSTALLATION OF DRY STAND PIPE 3.2 Pipe Laying and Fittings FITTINGS (USE B.I FITTINGS SCHED .40)	XXX XXXXXX	
ITEM	DESCRIPTION													
2.0	EARTHWORKS INSTALLATION OF DRY STAND PIPE 3.2 Pipe Laying and Fittings FITTINGS (USE G.I FITTINGS SCHED .40)													
XXX XXXXXX														
ITEM	DESCRIPTION													
2.0	EARTHWORKS INSTALLATION OF DRY STAND PIPE 3.2 Pipe Laying and Fittings FITTINGS (USE B.I FITTINGS SCHED .40)													
XXX XXXXXX														



Conforme:



ALLAN A. MARTIN, RMP
Project-in-Charge



ATTY. JOSEPHINE C. LATI-BAGAOISAN
Chairperson

